

**K.A.R. 5-25-5. Well equipment.** (a) Each non-domestic well, except any well authorized by a temporary permit, shall be equipped with a water flowmeter that meets or exceeds the requirements of subsection (c). Each non-domestic, non-temporary well not subject to regulation under the Kansas chemigation safety law, K.S.A. 2-3301 et seq. and amendments thereto, shall be equipped with an in-line, automatic, quick-closing check valve capable of preventing pollution of the source of water supply.

(b) Each check valve installed shall meet or exceed the specifications set forth in K.A.R. 5-6-13a.

(c) Each water flowmeter required by the board, or pursuant to a regulation adopted by the chief engineer, before the effective date of this regulation, shall meet or exceed applicable requirements of article 1 of the division's regulations. (Authorized by K.S.A. 82a-706a and K.S.A. 2002 Supp. 82a-1028; implementing K.S.A. 82a-706a and K.S.A. 2002 Supp. 82a-1028; effective May 1, 1980; amended May 1, 1985; amended April 19, 1996; amended Oct. 31, 2003.)